



NOTES:

1. HOLD ROUGH-IN DIMENSIONS ± 1/8" (3.2mm).
2. **WHEN INSTALLING THIS UNIT, LOCAL, STATE, OR FEDERAL CODES SHOULD BE ADHERED TO. FOR INSTALLATION HEIGHTS OTHER THAN SHOWN, DIMENSIONS MARKED (*) MUST BE ADJUSTED ACCORDINGLY.
3. DIMENSIONS ARE IN INCHES. DIMENSIONS IN PARENTHESES ARE IN MILLIMETERS.
4. ALLOW 4 INCHES (102mm) MINIMUM CLEARANCE FOR VENTILATION.

5. POWER FURNISHED WITH A 3 PRONG PLUG.
6. **INSTALLER SHOULD PROVIDE SUPPLY STOP FOR PROPER INSTALLATION.
7. SEE SHEET 2 FOR ROUGH-IN DIMENSIONS.
8. REFER TO 5874/VRK5874 O&M FOR PUSH BUTTON AND VALVE INSTALLATION AND MAINTENANCE INSTRUCTIONS.

REG. NO. 10/98

DATE 10/98

CHKD:

APPROVED:

MODEL(S): HWBFARL, VRC

INFO. FAX DOC #: 24925872

SCALE: 1/8" = 1"

INSTALLATION/FABRICATION

INFO FAX : 1-888-FAX-HAWS (1-888-329-4297)

1455 Kiappa Ln, Sparks NV, 89431

Phone: 775-359-4712 Fax: 775-359-7424

Haws Ag Building 3 CH-3401 Burgdorf Switzerland

Haws Mfg. Pte Ltd 74 Sungai Kodat Loop Singapore 729531

e-trail: Haws@hawsco.com website: www.hawsco.com

DATE: 02/08

REV: 080283 D

BY: 13792A00

CHKD: 13792A00

DATE: 09/07

SIZE: A

SHEET: 1 OF 2

